WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81768
Permit No.
Basin 42

NOTICE OF INTENT NO. 44896

1. OWNER JOANNA W. GREGORY
MAILING ADDRESS 583 MALLARD, HUMBOLDT RANCHETTS
HALLECK,, NV 89824

ADDRESS AT WELL LOCATION
UNIT #2, BLOCK B, LOT 3

2. LOCATION NW 1/4 NW 1/4 Sec. 3 T 36N N/S R 58E E ELKO County
PERMIT NO. 019002003 HUMBOLDT ACRES
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	2	2
SOFT SANDSTONE		2	78	76
BLUE CLAY		78	169	91
BLACK SAND	X	169	170	1
BLUE CLAY		170	184	14
BLACK SAND	X	184	186	2
BLUE CLAY		186	201	15
BLACK SAND	X	201	202	1
BLUE CLAY		202	212	10

RECEIVED
00 SEP 11 AM 11:57
STATE ENGINEER'S OFFICE

Date started 8/22/00, 19__
Date completed 8/24/00, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		10.5

8. WELL CONSTRUCTION

Depth Drilled 212 Feet Depth Cased 212 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	212 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	+2	212

Perforations:
Type perforation MILL SLOT
Size perforation 3/16" X 3"
From 191 feet to 212 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 54
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 54 feet to 212 feet

9. WATER LEVEL

Static water level 129 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Fertig Drilling Company
Contractor

Address P.O. BOX 525
Contractor

ELKO, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 0031904

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 8-29-00