

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48363

1. OWNER G & D PALMER ADDRESS AT WELL LOCATION 5650 MEACHAM WASHOE VALLEY
 MAILING ADDRESS 5650 MEACHAM WASHOE VALLEY NV 89704
 2. LOCATION NE 1/4 SW 1/4 Sec 14 T 16 S R 19 E WASHOE County
 PERMIT NO. 055 165 02 Parcel No. NA Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
PASTURE LOAM		0	2	2
SILTY GREY CLAY		2	11	9
BLK CLAYEY SILT SOME SAND/SOME SILT	X	11	43	32
BLK CLAY		43	47	4
LAYERED DARK CLAY WITH CLEAN DS FROM 118-120	X	47	120	73

RECEIVED
 00 SEP 20 AM 11:28
 WARE ENGINEERING CO. S. F. C. I.

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 120 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>13</u>	<u>.138</u>	<u>+2</u>	<u>120</u>

Perforations:
 Type perforation SAWCUT
 Size perforation 3x 3/8
 From _____ feet to _____ feet
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 120 feet to 100 feet

9. WATER LEVEL
 Static water level 2 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality _____

Date started 8/5 1900
 Date completed 8/28 1900

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50+</u>	<u>/</u>	<u>3</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name NEVADA DRILLING Contractor
 Address 75 LEWERS CRK RD Contractor
WASHOE VALLEY, NV 89704
 Nevada contractor's license number issued by the State Contractor's Board 13697A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790 1790
 Signed Joe Leisch
 By driller performing actual drilling on site or contractor
 Date 9/8/00