WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81810
Permit No.
Basin 101

NOTICE OF INTENT NO. 44144

1. OWNER Zelma Dunn
MAILING ADDRESS P.O. Box 538
Fallon, NV 89406

ADDRESS AT WELL LOCATION 17155 Reno Hwy, Fallon, NV 89406

2. LOCATION SE 1/4 NE 1/4 Sec. 5 T 19N N/S R 26E E Churchill County
PERMIT NO. _____ Issued by Water Resources | 07-011-50 Parcel No. | _____ Subdivision Name

3. **WORK PERFORMED**
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Gravl & Sand		0	20	20
Brown Clay		20	220	200
Gray Clay with Black		220		
Green sand			307	87
Sand Stone	X	307	340	33
Green Sand Stone	X	340	380	40

RECEIVED
00 SEP 14 AM 10:46
STATE ENGINEERS OFFICE

Date started 07/06/2000, 19__
Date completed 07/07/2000, 19__

7. **WELL TEST DATA**

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5-7		1 hr

8. **WELL CONSTRUCTION**

Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	380	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	20
6 PVC	3.92	.258	20	380

Perforations:
Type perforation Saw CUt
Size perforation 1/8
From 300 feet to 380 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 380 feet

9. **WATER LEVEL**

Static water level 120 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.
Contractor

Address P.O. Box 1264
Contractor

Fallon Nv. 89407

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wayne Parsons
By driller performing actual drilling on-site or contractor

Date 08/03/2000

USE ADDITIONAL SHEETS IF NECESSARY