WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81827
Permit No.
Basin 101

NOTICE OF INTENT NO. 42656

1. OWNER Environmental Company
MAILING ADDRESS 710 NW Juniper st Suite 208 Issaquah Wa 98027
ADDRESS AT WELL LOCATION 4755 Pasture Rd 348 Fallon NV 89496

2. LOCATION NW ¼ SW ¼ Sec. 15 T. 18 N/S R. 29 E. Churchill County
PERMIT NO. M10-200 Issued by Water Resources | Federal Facility Parcel No. | MW-348-C well id Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
1) Placed Neat Cement via Tremie pipe from Bottom of Hole in an upward direction to the top				
2) Depth of well 22				
3) Perforation 7' to 22'				
4) 12 GALLONS Cement PLACED IN well				

Date started 8-15 2000
Date completed 8-16 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 22 Feet Depth Cased 22 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	Factory	sch 40	0'	7

Perforations:
Type perforation sch 40 / slot
Size perforation .020
From 7' feet to 22' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal 22.5
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 7.15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Barnet Longyear Contractor
Address 32 Stokes dr Contractor
Dayton, NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2071
Signed By driller performing actual drilling on site or contractor
Date 9-6-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627