

OFFICE USE ONLY
 Log No. 81845
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21510

1. OWNER ROUSE FS LLC ADDRESS AT WELL LOCATION 3200 S. LAS VEGAS BLVD.
 MAILING ADDRESS PO BOX 833 FASHION SHOW MALL 2000
COLUMBIA, MD. 21044-0833

2. LOCATION NW 1/4 NW 1/4 Sec. 16 T 21 N/S R 61 E CLARK County
 PERMIT NO. DW-1124 162-17-510-001 NEIMAN MARCUS
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other Dewater

4. Dewater PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>4-DEWATER WELLS</u>				
<u>FILL</u>		<u>0</u>	<u>1</u>	<u>1</u>
<u>SANDY CLAY</u>		<u>1</u>	<u>8</u>	<u>7</u>
<u>CALICHE</u>		<u>8</u>	<u>12</u>	<u>4</u>
<u>SANDY GRAVEL</u>		<u>12</u>	<u>14</u>	<u>2</u>
<u>CALICHE</u>		<u>14</u>	<u>19</u>	<u>5</u>
<u>CLAY</u>		<u>19</u>	<u>30</u>	<u>11</u>

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)
 From 24 Inches 0 Feet To 30 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>14"</u>	<u>36.71</u>	<u>0.250</u>	<u>0</u>	<u>30'</u>

Perforations: Machine
 Type perforation _____
 Size perforation 1/4 x 2 1/2x
 From 10' feet to 30' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 0 feet to 30 feet

9. WATER LEVEL
 Static water level 12 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 11-13
 Date completed 11-14

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING INC. Contractor
 Address 4847 S. VALLEY VIEW Contractor
LAS VEGAS, NV 89103

Nevada contractor's license number 18917
 issued by the State Contractor's Board.

Nevada driller's license number issued by the 1301 T-1
 Division of Water Resources, the on-site driller.

Signed [Signature]
 By driller performing actual drilling on site or contractor

Date 12-4-00

