WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81850
Permit No.
Basin 101

NOTICE OF INTENT NO. 44224

1. OWNER Frank Woolsey
MAILING ADDRESS 2161 W Williams PMB 280
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4395 Hawk Dr Fallon Nv 89406

2. LOCATION NE 1/4 NE 1/4 Sec. 28 T 19 N/S R 28 E Churchill County
PERMIT NO. Issued by Water Resources | 008-281-73 Parcel No. | Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Brown Clay		0	10	10
Brown Sand		10	30	20
Gray Sand		30	58	28
Brown Sand	xx	58	68	10

RECEIVED
SEP 11 2000
NEVADA DIVISION OF WATER RESOURCES

Date started 04/17/2000 , 19__
Date completed 04/17/2000 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40		1

8. **WELL CONSTRUCTION**
Depth Drilled 68 Feet Depth Cased 68 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	68	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	10
6 pvc	3.92	.258	10	68

Perforations:
Type perforation saw cut
Size perforation 1/8"
From 63 feet to 38 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 60
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 60 feet to 68 feet

9. **WATER LEVEL**
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. Contractor
Address P.O. Box 1264 Contractor
Fallon Nv. 89407
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed [signature] By driller performing actual drilling on-site or contractor
Date 04/17/2000

USE ADDITIONAL SHEETS IF NECESSARY