

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20616

1. OWNER Nye County ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION NE 1/4 NE 1/4 Sec 7008 T 15S N/S R 49E F Nye County \_\_\_\_\_  
PERMIT NO. \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Hand Drilled

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Silty Gravelly Sand</u>		<u>0</u>	<u>15</u>	<u>15</u>
<u>Gravelly sand</u>		<u>15</u>	<u>45</u>	<u>30</u>
<u>Fine Gravel Fine Sand</u>				
<u>Silty sands with traces of gravel</u>		<u>45</u>	<u>85</u>	<u>40</u>
<u>Sandy gravels from fine to coarse</u>		<u>85</u>	<u>190</u>	<u>105</u>
<u>Sandy clay with graded sand and fine gravel</u>		<u>190</u>	<u>220</u>	<u>30</u>
<u>Sandy gravel coarse sand clayey often 235'</u>		<u>220</u>	<u>260</u>	<u>40</u>
<u>CLAYEY SANDY GRAVEL</u>		<u>260</u>	<u>275</u>	<u>15</u>
<u>COARSE SAND FINE GRAVEL</u>		<u>275</u>	<u>290</u>	<u>15</u>
<u>Tuff partially welded XTal Rich Very Hard Pink light gray</u>				

8. WELL CONSTRUCTION  
Depth Drilled 290 Feet Depth Cased 290 Feet  
HOLE DIAMETER (BIT SIZE)  
From 9 3/4 Inches To 0 Feet 290 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 7/8</u>			<u>72</u>	<u>290</u>

Perforations:  
Type perforation SLITTED  
Size perforation 0.20  
From 260 feet to 200 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 189 feet 0  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 274 feet to 191 feet

9. WATER LEVEL  
Static water level 210 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name LAYNE CHRISTENSEN Contractor  
Address 12050 E. ELIAS RD CHANDLER AZ 85249 Contractor  
Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1813-JT  
Signed Layne Christensen  
By driller performing actual drilling on site or contractor  
Date \_\_\_\_\_

Date started 25 FEB 2000  
Date completed 1 MAR 2000

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>5</u>	<u>60'</u>	<u>6 HRS</u>	

