81930

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 81930
Permit No.
Basin 212

NOTICE OF INTENT NO. 21962

1. OWNER Robert Worthen
MAILING ADDRESS 112 Worthen cir
Las vegas NV 89128

ADDRESS AT WELL LOCATION Gagne Coach
1301 N. Main st.
Las vegas NV

2. LOCATION SE ¼ NE ¼ Sec. 27 T. 20 N/S R. 61 E. Clark County

PERMIT NO. ____ Issued by Water Resources | 139-27-502-007 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphault		0	.5	.5
Sand w/gravel		.5	2.0	1.5
Silty clay w/sand	15	2.0	25	23

DCNR/DWR Received 2 2001 LAS VEGAS OFFICE

Date started Dec 20, 2000 ~~19~~
Date completed Dec 20, 2000 ~~19~~

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10" Inches	0 Feet	25 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		Sch 40	0	30'

Perforations:
Type perforation Factory slot
Size perforation .020
From 10 feet to 25 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 8 to 0'
Placement Method: ☐ Pumped ☑ Poured

Seal Type:
☐ Neat Cement
☑ Cement Grout
☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 8' feet to 25 feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Compliance drilling
Contractor
Address 3915 W. Hacienda
Contractor
Las vegas NV. 89118

Nevada contractor's license number issued by the State Contractor's Board 0048704

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869

Signed [signature]
By driller performing actual drilling on site or contractor

Date Dec 26, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627