



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20682

1. OWNER STATE OF NEVADA DEPT. OF TRANSPORTATION ADDRESS AT WELL LOCATION INTERSTATE 15 FROM SAHARA AVE. (SR589) TO CHARLESTON BLVD (SR159)  
 MAILING ADDRESS 1263 S. STEWART STREET CARSON CITY, NV 89712 CONTRACT # 3003  
 2. LOCATION NE 1/4 NE 1/4 Sec. 8 T. 21 N/S R. 61 E CLARK County  
 PERMIT NO. DW1118 162-04-401-001-003 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. Dewater PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Angel

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Abandon 13-30' dewater wells				
Pulled casings				
No access for drill rig				
Filled with 4 yards of 9 sac cement slurry each.				

8. WELL CONSTRUCTION  
 Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)  
 From 24 Inches 0 Feet 30 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14"	36.71	.250	+2	-30

Perforations: Machine  
 Type perforation \_\_\_\_\_  
 Size perforation 1 7/8" x 2 1/2" x 21 per ft.  
 From 10 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  
 Poured  
 Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

Date started 11-21 2000  
 Date completed 12-7 2000

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ALLEN DRILLING INC.  
 Address 4847 S. VALLEY VIEW LAS VEGAS, NV 89103  
 Nevada contractor's license number 18917 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1301 Division of Water Resources, the on-site driller.  
 Signed Allen B. Allen  
 By driller performing actual drilling on site or contractor  
 Date 1-8-01