WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82007
Permit No.
Basin 221

NOTICE OF INTENT NO. 36021

1. OWNER Vidler Water Company, Inc.
MAILING ADDRESS 3264 Goni Road, Ste. #143
Carson City, NV 89706-7925

ADDRESS AT WELL LOCATION 50 miles south of Caliente, Nevada
TULE DESERT VALLEY

2. LOCATION SW ¼ NW ¼ Sec. 4 T 10 N/S R 69 E Lincoln County
PERMIT NO. ~~N-2093~~ (Issued by Water Resources) N/A (Parcel No) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☒ Air ☐ Other Flooded ~~Reverse~~

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand and Gravel		0	220	220
Clays		220	465	245
Clays and Gravel		465	835	370
Dolamite and Limestone		835	1500	665
Sandstone	X	1500	1642	140
Clays and Sandstone		1640	1900	260

Date started November 2, 2000
Date completed November 16, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		15 hours

8. WELL CONSTRUCTION
Depth Drilled 1900 Feet Depth Cased 1040 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
14 3/4 Inches		0 Feet	220 Feet
9 7/8 Inches		20 Feet	1050 Feet
6 1/2 Inches		1050 Feet	1900 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	32.75	.250	0	20
2 3/8	3.65	SCH 40	0	690
2 3/8	3.65	SCH 40	0	950

Perforations:
Type perforation Slot
Size perforation 3" x 1/8"
From 690 feet to 730 feet
From 950 feet to 1040 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 665
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From 665/935 feet to 770/1040 feet

9. WATER LEVEL
Static water level 453 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2745 W. California Ave. (Contractor)
Salt Lake City, UT 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2102
Signed Jeff Kane (By driller performing actual drilling on site or contractor)
Date 12-8-2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-027