WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82008
Permit No.
Basin 221

NOTICE OF INTENT NO. 36004

1. OWNER Vidler Water Company
MAILING ADDRESS 3264 Goni Road, Suite #143
Carson City, NV 89006-7925

ADDRESS AT WELL LOCATION 50 miles south of Caliente, NV
Tule Desert Valley

2. LOCATION NW ¼ NW ¼ Sec. 23 T 9 N/S R 69 E Lincoln County
PERMIT NO. ~~W-2099~~ (Issued by Water Resources) N/A (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [X] RVC
[X] Air [ ] Other Flooded Reversible

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		0	380	380
Clays & Gravel		380	1200	820
Limestone & Clays	X	1200	2065	865

NOTE: Bottom part of the hole (from 1550' to 2065') was filled with hole plug.

Date started November 16, 2000
Date completed December 9, 2000

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		

8. WELL CONSTRUCTION
Depth Drilled 2,065 Feet Depth Cased 1,540 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
14 3/4 Inches	0 Feet	20 Feet
9 7/8 Inches	20 Feet	1550 Feet
6 1/4 Inches	1550 Feet	2065 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10	32.75	.250	0	20
2 3/8	3.65	SCH 40	0	740
2 3/8	3.65	SCH 40	0	1540

Perforations:
Type perforation Slot
Size perforation 3" x 1/8"
From 635 feet to 740 feet
From 1435 feet to 1540 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 470
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 597/1420 feet to 755/1550 feet

9. WATER LEVEL
Static water level 508 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address 2745 W. California (Contractor)
Salt Lake City, UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2102

Signed Jeff Kassi
By driller performing actual drilling on site or contractor
Date 12-14-2000

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627