

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20694

1. OWNER John C Leavitt ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
3551 S. Seneca St. Pahrump, NV 89048 3551 S. Seneca St. Pahrump, NV
 2. LOCATION NE 1/4 SW 1/4 Sec. 36 T. 20S N/S R. 53E E. Nye County
 PERMIT NO. N/A 41-123-02 N/A Subdivision Name _____
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------------|--------------|------|-----|------------|
| Brown Clay | | 0 | 8 | 8 |
| Grey Clay | | 8 | 14 | 6 |
| Caliche | | 14 | 29 | 15 |
| Dark Brown Clay | X | 29 | 74 | 45 |
| Grey Clay | X | 74 | 90 | 16 |
| Light Brown Clay | X | 90 | 120 | 30 |
| Caliche | X | 120 | 140 | 20 |

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>12</u> | <u>17</u> | <u>.188</u> | <u>0</u> | <u>14</u> |

Perforations:
 Type perforation Parton
 Size perforation 3x4x6
 From _____ feet to _____ feet
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50 feet to 140 feet

Date started December 12, 2000
 Date completed January 20, 2001

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|-----------|-------------------------------|--------------|
| <u>30</u> | <u>5</u> | <u>1/2</u> |

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Larry Water Well Service Contractor
 Address P.O. Box 3392 Contractor
Pahrump, Nevada 89041
 Nevada contractor's license number issued by the State Contractor's Board 0035901
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
 Signed Larry Jenkins
 By driller performing actual drilling on site or contractor
 Date January 30, 2001

