

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20283

1. OWNER American Prodr Corp  
MAILING ADDRESS 3770 HOWARD HUGHES  
PLAZA #306 L.V. NV 89107  
2. LOCATION 7000 1/4 NW 1/4 Sec. 22 T. 49N R. 62E County  
PERMIT NO. 145-36-499-000  
Issued by Water Resources 1/15/00 Parcel No. 145-36-499-000

ADDRESS AT WELL LOCATION  
STREET LIGHT # 1117  
SECRET # 10000000 ON ATTEN  
CLARK

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>BRK CONCRETE CAP</u>				
<u>pulled 2-2" both</u>				
<u>BRK FREE KNOCED</u>				
<u>BOSTON OOL AND POMPED</u>				
<u>80 gal of Bentonite grout</u>				
<u>grout settled 40 4'</u>				
<u>Capped with 4' concrete-</u>				
<u>TO SURFACE</u>				

8. WELL CONSTRUCTION  
Depth Drilled 47 Feet Depth Cased 47 Feet  
HOLE DIAMETER (BIT SIZE)  
From 8 Inches To 47 Feet  
Inches Feet Feet  
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>		<u>sch. 40</u>		

Perforations:  
Type perforation machine slotted  
Size perforation 220  
From 27 feet to 47 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal \_\_\_\_\_  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 25 feet to 47 feet

9. WATER LEVEL  
Static water level 36 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 7-26 2000  
Date completed 7-26 2000

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Eagle Drilling L.L.C. Contractor  
Address 7150 Phoenia St Contractor  
L.V. NV 89117  
Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2107  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 7-26-2000