WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 83096
Permit No.
Basin 107

NOTICE OF INTENT NO. 33431

1. OWNER Charles Johnson
MAILING ADDRESS 2781 Pug HLO Pu ST. Kiohel Maui Hawaii
ADDRESS AT WELL LOCATION 3 B Copper belt Rd. Smith Nev 89430

2. LOCATION SW ¼ SW ¼ Sec. 13 T 10 N/S R 24 E Lyon County
PERMIT NO. Issued by Water Resources | 01047114 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Top Soil		0	28	28
And cobble stones		~~28~~	~~78~~	~~50~~
Sandy Clay	yes	28	78	50
Gray sandy clay with coarse stratta of sand in between	yes	78	140	62
Gray clay with some sand stratta	yes	140	200	60

Date started 10-9, 19 2000
Date completed 10-15, 19 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	10 ft	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 145 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	100 Feet
6 5/8 Inches	100 Feet	200 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		185	0	145

Perforations:
Type perforation Factory Saw Slott
Size perforation 3/32 x 3
From 75 feet to 155 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Contractor
Address P.O. Box 92 Contractor
Smith Nev 89430
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 716
Signed Edmund Miller
By driller performing actual drilling on site or contractor
Date 10-16-00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627