

COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 82106  
 Permit No. 05  
 Basin 42008  
 NOTICE OF INTENT NO. 42008  
 ADDRESS AT WELL LOCATION 225 AUTUMN HILLS RD  
GARDNERVILLE, NV 89410

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER CHUCK PAYA CONSTRUCTION  
 MAILING ADDRESS 402 FOOTHILLS RD  
GARDNERVILLE, NV 89410  
 ADDRESS AT WELL LOCATION 225 AUTUMN HILLS RD  
GARDNERVILLE, NV 89410

2. LOCATION NW 1/4 NW 1/4 Sec 10 T 12 N R 19 E DOUGLAS County  
 PERMIT NO. 19-350-060  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
LARGE GRANITE BOULDER		0	6	6
LARGE GRANITE BOULDERS AND SAND		6	69	63
COURSE DG SANDS AND COBBLES		69	110	41
DG GRANITE SANDSTONE ROCK		110	145	35
FRACTURED GRANITE HARD GRANITE BOULDERS	XXX	145	180	35

8. WELL CONSTRUCTION

Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 3/4 Inches To 0 Feet 180 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	180

Perforations:  
 Type perforation FACTORY MILL SLOT  
 Size perforation 3 X 3/32

From 160 feet to 180 feet  
 \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 55 feet to 180 feet

9. WATER LEVEL  
 Static water level 65 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 2.5 + P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)  
 Address 20 KIT KAT DRIVE  
 (CONTRACTOR)  
CARSON CITY, NV 89701  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10/17/00

Date started 10/13, 20 00  
 Date completed 10/17, 20 00

7. WELL TEST DATE

TEST METHOD:  Bailer  Pump  Air Lift  
 Draw Down (Feet Below Static) Time (Hours)

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25 +</u>	<u>40</u>	<u>3 HRS</u>

RECEIVED  
 00 NOV - 1 AM 8:28  
 STATE ENGINEER'S OFFICE