WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82108
Permit No.
Basin 105

NOTICE OF INTENT NO. 44905

1. OWNER Randall Tanaka
MAILING ADDRESS 1830 Helman Dr.
Gardnerville., NV 89410

ADDRESS AT WELL LOCATION 1830 Helman Dr.
Gardnerville Nv.

2. LOCATION NW 1/4 SW 1/4 Sec. 12 T 12N N/S R 20E E Douglas County
PERMIT NO. Issued by Water Resources
1220-12-3 Parcel No.
Pinenut Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Small gravel & sand	no	0	19	19
Sandy clay	no	19	71	52
Unsorted med. to small gravel	yes	71	138	67
Med to large cobbles	yes	138	154	16
Unsorted small cobbles and pebbles	yes	154	200	46

RECEIVED
00 NOV -8 AM 11:32
INTERBASIN OFFICE

Date started 10/11/2000, 19__
Date completed 10/14/2000, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air lift	28		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	19	.188	+2	200

Perforations:
Type perforation Factory Milled
Size perforation 1/8 X 3
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50ft
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 90ft. feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc. Contractor
Address 7780 Curry Rd. Contractor
Fallon,Nv. 89406
Nevada contractor's license number issued by the State Contractor's Board 27673-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed By driller performing actual drilling on-site or contractor
Date 10/16/2000

USE ADDITIONAL SHEETS IF NECESSARY