

- COPIES TO  
 - DIVISION OF WATER RESOURCES  
 - CLIENT'S COPY  
 - WELL DRILLER'S COPY

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 82112  
 Permit No. 105  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 42021

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER BLAIN MCGUIRE CONSTRUCTION ADDRESS AT WELL LOCATION 629 STALLION  
 MAILING ADDRESS 2110 EASTLAKE BLVD GARDNERVILLE, NV 89410  
CARSON CITY, NV 89704

2. LOCATION SE 1/4 SE 1/4 Sec 24 T 12 N R 20 E DOUGLAS County  
 PERMIT NO. 1220-24-401-017

Issued by Water Resources Parcel No. Subdivision Name  
 3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
HARD PAN CLAY		0	8	8
COURSE SANDS		8	39	31
BROWN CLAY STRATA		39	76	37
COURSE COBBLES		37	134	97
OBSIDIAN GRAVELS				
BROWN CLAY		134	165	31
VERY FRACTURED VOLCANIC OBSIDIAN GRAVELS	<u>XXX</u>	165	190	25

8. WELL CONSTRUCTION  
 Depth Drilled 190 Feet Depth Cased 190 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
10 3/4 Inches 0 Feet 190 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>190</u>

Perforations:  
 Type perforation FACTORY MILL SLOT  
 Size perforation 3 X 3/32  
 From 170 feet to 190 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 190 feet

9. WATER LEVEL  
 Static water level 80 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25 P.S.I.  
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name CAPITAL CITY WELL DRILLING  
 (CONTRACTOR)  
 Address 20 KIT KAT DRIVE  
 (CONTRACTOR)  
CARSON CITY, NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board 41775  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael P. Had  
 By driller performing actual drilling on site or contractor  
 Date 1/12/01

Date started 12/19, 20 00  
 Date completed 12/21, 20 00

7. WELL TEST DATE

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>	<u>25</u>	<u>3 HRS</u>

RECEIVED  
 01 JAN 17 AM 8:17  
 STATE ENGINEERS OFFICE