COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

# DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82123
Permit No.
Basin 105
NOTICE OF INTENT NO. 42004

1. OWNER D E JANSSE & CO.
MAILING ADDRESS 1589 SARARATOGA CIR
MINDEN NV 89423

ADDRESS AT WELL LOCATION 2618 ERIN CRT
GARDNERVILLE NV 89410

2. LOCATION NW ¼ SE ¼ Sec 2 T 13 N R 20 E DOUGLAS County

PERMIT NO. (Issued by Water Resources) | 23-090-730 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| OVER BURDEN | | 0 | 3 | 3 |
| DG SANDS AND SMALL | | 3 | 78 | 75 |
| SANDS | | | | |
| BROWN HARDPAN | | 78 | 146 | 68 |
| CLAY | | | | |
| DG SANDS WITH CLAY | | 146 | 234 | 88 |
| SEAMS | | | | |
| GUMMY BROWN CLAY | | 234 | 248 | 14 |
| FRACTURED OBSIDIAN | | | | |
| SANDS AND GRAVELS | | 248 | 280 | 32 |

Date started 9/12, 20 00
Date completed 9/15, 20 00

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 22 | 50 | 3 HRS |

8. WELL CONSTRUCTION

Depth Drilled 280 Feet Depth Cased 280 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 3/4 Inches | 0 Feet | 280 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.03 | .188 | 0 | 280 |

Perforations:
Type perforation MILL SLOT
Size perforation 3 X 3/32
From 260 feet to 280 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 280 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow G.P.M 22 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMPS (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 41775
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 9-18-00