

OFFICE USE ONLY  
 Log No. 82132  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43093

1. OWNER A. York ADDRESS AT WELL LOCATION 1464 CARLSON  
 MAILING ADDRESS 1464 CARLSON GV, NV 89423  
 2. LOCATION NE 1/4 SW 1/4 Sec. 32 T. 13 S. R. 21 E. Douglas County  
 PERMIT NO. 23 180 50 Parcel No. NA Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAYEY SILT		0	3	3
COBBLES + GRVL W		3	25	22
BROWN CLAYEY SILT				
LITTLE SAND				
GRVL, SAND, SILT	X	25	150	125
SOME CLAY				
SILTY BROWN CLAY		150	170	20
GRVLY BROWN CLAY		170	190	20
SMALLER GRVLS W	X	190	220	30
LITTLE BROWN CLAY				
BROWN CLAYEY SAND		220	240	20
GRVL W BROWN CLAY	X	240	255	15

8. WELL CONSTRUCTION  
 Depth Drilled 255 Feet Depth Cased 255 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/4 Inches To 2 1/2 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 7/8</u>		<u>.188</u>	<u>+2</u>	<u>255</u>

Perforations:  
 Type perforation FACTORY CUT  
 Size perforation 3 x 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 235 feet to 255 feet  
 From 195 feet to 215 feet  
 From 155 feet to 175 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 255 feet

Date started 1/18 1900  
 Date completed 2/2 1900

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50+</u>	<u>1</u>	<u>3</u>

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING, Inc Contractor  
 Address 75 LEWERS CRK RD Contractor  
CARSON CITY, NV 89704  
 Nevada contractor's license number issued by the State Contractor's Board 13697A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790  
 Signed Joe Reisch  
 By driller performing actual drilling on site or contractor  
 Date 9/5/00