

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY  
Log No. 82137  
Permit No. 104  
Basin 104

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 44477

1. OWNER Gil Goode ADDRESS AT WELL LOCATION 2611 Snyder Lane  
MAILING ADDRESS 1402 Marlette Circle  
Gardnerville, NV 89410

2. LOCATION NW 1/4 SW 1/4 Sec. 2 T 14N N/S R 20E E Carson County  
PERMIT NO. 10-281-32 Parcel No. 10-281-32 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Domestic  
 Deepen  Abandon  Other  Municipal/Industrial  Irrigation  Monitor  Test  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Weathered granite</u>	<u>x</u>	<u>125</u>	<u>147</u>	<u>22</u>
<u>Granite</u>	<u>x</u>	<u>147</u>	<u>203</u>	<u>56</u>
<u>Weathered granite</u>	<u>x</u>	<u>203</u>	<u>307</u>	<u>104</u>
<u>Granite</u>	<u>x</u>	<u>307</u>	<u>325</u>	<u>18</u>
<u>Original well was 8 5/8"</u>				

8. WELL CONSTRUCTION  
Depth Drilled 325 Feet Depth Cased 325 Feet  
HOLE DIAMETER (BIT SIZE)  
7 7/8 Inches From 125 Feet To 325 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5</u>	<u>10.79</u>	<u>.188</u>	<u>115</u>	<u>325</u>

Perforations:  
Type perforation Factory  
Size perforation 3/32 x 3"  
From 245 feet to 265 feet  
From 305 feet to 325 feet

Surface Seal:  Yes  No  
Depth of Seal \_\_\_\_\_  
Placement Method:  Pumped  Poured  
Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
Gravel Packed:  Yes  No  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
Static water level 20 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature Cold °F Quality Not tested

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Bruce MacKay Pump & Well Service, Inc. Contractor

Date started 12/18/2000 19\_\_\_\_  
Date completed 12/20/2000 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<u>Air lift</u>	<u>27</u>	<u>230</u>	<u>2 hours</u>

Address 1600 Mt. Rose Hwy Contractor  
Reno, NV 89511  
Nevada contractor's license number issued by the State Contractor's Board 23096  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719  
Signed R. Bruce MacKay  
By driller performing actual drilling on-site or contractor  
Date 12/19/00