

OFFICE USE ONLY  
Log No. 82142  
Permit No. 105  
Basin. \_\_\_\_\_

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43359

1. OWNER George + Chris MALYSHEFF ADDRESS AT WELL LOCATION 2666 Billy's Road  
MAILING ADDRESS 2666 Billy's Road Minden NV 89423 Minden NV 89423  
2. LOCATION NE 1/4 SW 1/4 Sec 32 T 14 N R 20 E Douglas County  
PERMIT NO. 24696 • CERT 8284 21 020 48 Issued by Water Resources Parcel No. Subdivision Name

55899

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown clay		0	5	5
Black sand w/some Brown clay layers BB size gravel		5	140	135
Black clay		140	160	20
SANDY pea size gravel Brown Reddish Blackish		160	165	5
SANDY BROWN clay		165	185	20
SANDY pea size gravel w/a few clay layers Brown Reddish Blackish greenish		185	303	118

8. WELL CONSTRUCTION  
Depth Drilled 303 Feet Depth Cased 300 Feet  
HOLE DIAMETER (BIT SIZE)  
From 14.5 Inches To 0 Feet 303 Feet  
CASING SCHEDULE  
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)  
8 5/8 188 2 200  
Perforations:  
Type perforation FACTORY SLOT  
Size perforation 3/32"  
From 200 feet to 300 feet  
Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
Depth of Seal 100'  
Placement Method:  Pumped  Poured  
Gravel Packed:  Yes  No  
From 100 feet to 303 feet  
9. WATER LEVEL  
Static water level: 39' feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 58 °F Quality GOOD

Date started 7-24 00  
Date completed 8-1 00

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>500+</u>		

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name NEVADA DRILLING INC Contractor  
Address 75 LEWERS CREEK RD Contractor  
CARSON CITY NV 89704  
Nevada contractor's license number issued by the State Contractor's Board: 13697A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1902  
Signed John B. Smith  
By driller performing actual drilling on site or contractor  
Date 8-9-00