

OFFICE USE ONLY  
 Log No. 82143  
 Permit No. 105  
 Basin.....  
 NOTICE OF INTENT NO. 43355

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER WAYNE FERREE + DIANE PHILLIPS ADDRESS AT WELL LOCATION  
 MAILING ADDRESS 880 MEADOW VISTA CARSON CITY, NV 89705 991 STEPHANIE LANE MINDEN, NV  
 2. LOCATION NE 1/4 NE 1/4 Sec. 31 T. 14 S. R. 20 E Douglas County  
 PERMIT NO. 2129008 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>SANDY CLAY</u> <u>Brown</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>BLACK SAND w/VERY</u> <u>SMALL GRAVEL</u> <u>BROWNISH</u>		<u>5</u>	<u>70</u>	<u>65</u>
<u>BROWN CLAY</u>		<u>70</u>	<u>90</u>	<u>20</u>
<u>BLACK SAND w/SMALL</u> <u>PEASIZE GRAVEL BROWNISH</u> <u>BROWN CLAY</u>		<u>90</u>	<u>130</u>	<u>40</u>
		<u>130</u>	<u>143</u>	<u>13</u>

8. WELL CONSTRUCTION  
 Depth Drilled 143 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 143 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+3</u>	<u>90</u>
<u>6 5/8</u>		<u>.188</u>	<u>130</u>	<u>140</u>

Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 3/32  
 From 90' feet to 130' feet  
 From..... feet to..... feet  
 From..... feet to..... feet  
 From..... feet to..... feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 143 feet

9. WATER LEVEL  
 Static water level 6+- feet below land surface  
 Artesian flow..... G.P.M. P.S.I.  
 Water temperature 56 °F Quality OK

Date started 7-17 00  
 Date completed 7-24 00

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>100+</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING INC Contractor  
 Address 75 LEWERS CREEK RD Contractor  
CARSON CITY NV 89704  
 Nevada contractor's license number 13697A issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 1902 Division of Water Resources, the on-site driller.  
 Signed John B. Leiseh by driller performing actual drilling on site or contractor  
 Date 7-30-00