

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45105

1. OWNER M & P CUSTIS ADDRESS AT WELL LOCATION 2797 NYE DR
MAILING ADDRESS 2797 NYE DR MINDEN
MINDEN, NV 89423
2. LOCATION NE 1/4 NW 1/4 Sec. 35 T. 14 S. R. 20 E DOUGLAS County
PERMIT NO. 142035-104024 NA Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|--------------------------|--------------|------------|------------|------------|
| <u>SANDY BROWN CLAY</u> | | | | |
| <u>TO CLAYEY SAND</u> | | <u>0</u> | <u>220</u> | <u>220</u> |
| <u>HO GRAY CLAY</u> | | <u>220</u> | <u>235</u> | <u>15</u> |
| <u>SANDY, SMALL GRVL</u> | | <u>235</u> | <u>240</u> | <u>5</u> |
| <u>GRAY CLAY</u> | | <u>240</u> | <u>280</u> | <u>40</u> |
| <u>SMALL GRVL</u> | <u>X</u> | <u>280</u> | <u>295</u> | <u>15</u> |
| <u>GRAY CLAY</u> | | <u>295</u> | <u>330</u> | <u>35</u> |
| <u>BROKEN GRV VOL</u> | <u>X</u> | <u>330</u> | <u>380</u> | <u>50</u> |

8. WELL CONSTRUCTION
Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)
From 10 7/8 Inches To 0 Feet 380 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 7/8</u> | <u>13</u> | <u>.188</u> | <u>+2</u> | <u>380</u> |

Perforations:
Type perforation SAWCUT
Size perforation 3 x 3/32
From _____ feet to _____ feet
From 360 feet to 380 feet
From 320 feet to 340 feet
From 280 feet to 300 feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 FT Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 380 feet

9. WATER LEVEL
Static water level 190 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature COLD °F Quality _____

Date started 10/27 1900
Date completed 11/3 1900

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>20+</u> | <u>/</u> | <u>2</u> |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA DRILLING, INC Contractor
Address 75 LEWERS CRK RD Contractor
WASHOE VALLEY, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Keiser
By driller performing actual drilling on site or contractor
Date 11/9/00