WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82153
Permit No.
Basin 87

NOTICE OF INTENT NO. 44475

1. OWNER Anna Ross c/o Broadbent & Associates
MAILING ADDRESS 118 West St.
Reno, NV 89501

ADDRESS AT WELL LOCATION 118 West St. Reno, NV

2. LOCATION NW 1/4 SE 1/4 Sec. 11 T 19N N/S R 19E E Washoe County
PERMIT NO. Issued by Water Resources | 11-042-12 Parcel No. | Subdivision Name

3. WORK PERFORMED
- [ ] New Well
- [ ] Replace
- [ ] Recondition
- [ ] Deepen
- [x] Abandon
- [ ] Other

4. PROPOSED USE
- [ ] Domestic
- [ ] Irrigation
- [ ] Test
- [ ] Municipal/Industrial
- [x] Monitor
- [ ] Stock

5. WELL TYPE
- [ ] Cable
- [ ] Rotary
- [ ] RVC
- [ ] Air
- [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| On this date we abandoned the 2" monitor well by pumping neat cement mixed at 5.2 gallons of water per sack using tremie and filling from bottom. We displaced the water but the grout pump failed with cement at 15'. We then "topped off" using neat cement mixture and poured from top. | | | | |

Date started 12/6/2000, 19__
Date completed 12/6/2000, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION

Depth Drilled 28.5 Feet Depth Cased 28.5 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | | Sch 40 | 0 | 28.5 |

Perforations:
Type perforation Factory screen
Size perforation .020
From 8 feet to 28.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [x] Yes [ ] No
Depth of Seal 28.5
Placement Method: [x] Pumped [ ] Poured
Seal Type: [x] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [x] Yes [ ] No
From 7 feet to 28.5 feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Not Tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 12/6/00

USE ADDITIONAL SHEETS IF NECESSARY