

OFFICE USE ONLY  
 Log No. 82157  
 Permit No. 92A  
 Basin 92A

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43879

1. OWNER JOHN MERLINO ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 10950 Silver Knolls Blvd.  
Reno, Nevada 89506

2. LOCATION SW 1/4 SW 1/4 Sec 24 T. 21 19N N/S R. 18 Washoe County  
 PERMIT NO. 086-205-24 Silver Knolls  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING				
Wet bottom @225 feet				
Brown sandy clay		225	232	7
Soft zone		232	233	1
Brown sandy clay		233	263	30
Soft zone	X	263	272	9
Brown sandy clay		272	285	13
Soft zone	X	285	293	8
Brown sandy clay		293	303	10
Soft zone		303	304	1
Brown sandy clay		304	313	9

8. WELL CONSTRUCTION  
 Depth Drilled 313 Feet Depth Cased 313 Feet

HOLE DIAMETER (BIT SIZE)  
 From 6 1/8 Inches To 225 Feet  
313 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	313

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 226 feet to 246 feet  
 From 266 feet to 306 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal deepening  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 225 feet to 313 feet

9. WATER LEVEL  
 Static water level 237 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 15 P.S.I.  
 Water temperature cold °F Quality clear

Date started September 8, 2000, 19\_\_\_\_  
 Date completed September 9, 2000, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 0022549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date September 11, 2000