

OFFICE USE ONLY  
 Log No. 82158  
 Permit No. \_\_\_\_\_  
 Basin. 22A

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 40366

1. OWNER BILL & CAROL BAKER ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS 11575 Osage Road  
Reno, Nevada 89506  
 2. LOCATION NE 1/4 NE 1/4 Sec 24 T 21N N/S R 18 E Washoe County  
 PERMIT NO. 086-232-05 Silver Knolls Subdivision Name  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING				
Bottom of casing at 149 feet				
Rocks		148	149	1
Medium sand		149	159	10
Brown sandy clay		159	171	12
Decomposed granite, some clay streaks	X	171	205	34
Brown sandy clay		205	214	9
Brown clay with sand streaks	X	214	239	25
Brown clay		239	247	8
Medium to coarse sands	X	247	271	24
Brown sandy clay		271	277	6

8. WELL CONSTRUCTION  
 Depth Drilled 277 Feet Depth Cased 277 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
6 Inches 148 Feet 277 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	277

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 5 around  
 From 191 feet to 271 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Depth of Seal deepening  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 148 feet to 277 feet

9. WATER LEVEL  
 Static water level 130 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 17 P.S.I.  
 Water temperature cold °F Quality clear

Date started September 25, 2000, 19\_\_\_\_  
 Date completed September 27, 2000, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>17</u>		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number 0022549  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 923  
 Division of Water Resources, the on-site driller.  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date September 29, 2000