WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82165
Permit No.
Basin 72

NOTICE OF INTENT NO. 43489

1. OWNER FLORIDA CANYON MINING
MAILING ADDRESS P.O. BOX 330
IMLAY, NV 89418

ADDRESS AT WELL LOCATION
8 MILES SW OF IMLAY, NV
FLORIDA CANYON MINESITE

2. LOCATION NW ¼ NW ¼ Sec. 11 T. 31 N N/S R. 33 E E. PERSHING County
PERMIT NO. M/O 1112 (Issued by Water Resources) FLORIDA CANYON (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
MONITOR WELL MW23B				
ORIGINAL NOTICE #35453				
WELL ABANDONED				
HOLE WAS CHECKED FOR WATER WATER AT 302 FT.				
20 to 597 FT. BENTONITE GROUT IN UPWARD DIRECTION FROM BOTTOM				
49 - 50# BAGS BENTONITE MIXED WITH WATER				
SURFACE TO 20 FT. 3 - 94# BAGS PORTLAND CEMENT MIXED WITH WATER				

Date started SEPTEMBER 6, 2000
Date completed SEPTEMBER 6, 2000

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 597 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8			+2	597

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 20 FT.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 302 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DELONG CONSTRUCTION & DRILLING, INC. (Contractor)
Address P.O. BOX 907 WINNEMUCCA, NV 89446 (Contractor)
CONTRACTORS LICENSE #002120c

Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375

Signed
By driller performing actual drilling on site or contractor
Date SEPTEMBER 21, 2000

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627