WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 8216
Permit No.
Basin 72

NOTICE OF INTENT NO. 44887

1. OWNER Kimberly Harnes
MAILING ADDRESS P.O. Box 457
Gabbs, NV 89409

ADDRESS AT WELL LOCATION Hwy 400 Unionville, NV

2. LOCATION NE 1/4 NW 1/4 Sec. 33 T 32N N/S R 35E E Pershing County
PERMIT NO. _____ Issued by Water Resources
008-550-05 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay w/cobbles		0	30	
sand & clay		30	70	40
consoldated sand		70	90	20
sandy clay		90	190	100
consoldated sand		190	225	35
white clay		225	230	5

RECEIVED
00 NOV 27 PM 12: 22
STATE ENGINEER'S OFFICE

Date started 11/6/00 , 19__
Date completed 11/8/00 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8		4 hrs

8. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
11	Inches	0	Feet	50	Feet
9-7/8	Inches	50	Feet	230	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8		.188	+2	190

Perforations:
Type perforation mill slot
Size perforation 1/8 x 3
From 190 feet to 230 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 230 feet

9. WATER LEVEL
Static water level 160 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. Contractor
Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
Signed [signature] By driller performing actual drilling on-site or contractor
Date 11/22/00