WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82171
Permit No.
Basin 87

NOTICE OF INTENT NO. 44442

1. OWNER Brenda Nance
MAILING ADDRESS 7475 Shadow Lane
Sparks, NV 89434

ADDRESS AT WELL LOCATION 7475 Shadow Lane

2. LOCATION SW 1/4 SE 1/4 Sec. 27 T 20N N/S R 20E E Washoe County
PERMIT NO. WaCo#6727 Issued by Water Resources | 035-310-31 Parcel No. | Subdivision Name

3. WORK PERFORMED
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned the 6" domestic well. We perforated the well from approximately 110' to 20'. We then pumped approximately 1.5 cu. yards of neat cement mixed 5.2 gallons/sack from bottom of well to top using tremie pipe. We cut the top 2' off of the well and filled cement to surface.				

Date started 10/9/2000 , 19__
Date completed 10/10/2000 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 116 Feet Depth Cased 116 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"				

Perforations:
Type perforation Mills Knife
Size perforation puncture
From 110 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [ ] Yes [X] No
Depth of Seal
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 18 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay by driller performing actual drilling on-site or contractor
Date 10/10/00

USE ADDITIONAL SHEETS IF NECESSARY