

Permits 68313-5, 70762-3

WHITE-DIVISION OF WATER RESOURCES
CANARY-CLIENT'S COPY
PINK-WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 82188
Permit No. 87
Basin. 87
NOTICE OF INTENT NO. 38654

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

14ADA

1. OWNER Carl Harold
MAILING ADDRESS 1230 Riverberry Dr. Reno, NV 89509
ADDRESS AT WELL LOCATION Grass Valley Rd. North Palamino Valley NV 89506
2. LOCATION SE 1/4 NE 1/4 Sec 14 T 23 N 20 E Washoe County
PERMIT NO. N/A 076-320-03
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Red Clay w/rock stringers		206	230	
Brown Clay w/multi-colored volc. rock		230	242	
White Clay		242	257	
Brown Clay		257	308	
Gray Granitic rock		308	345	
Brown Clay		345	350	

RECEIVED
00 SEP 28 AM 11:08
STATE ENGINEER'S OFFICE

NS 9866219
W 119.645509 NAD27
reopening of Log # 47286

8. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 350 Feet
HOLE DIAMETER (BIT SIZE)
From To
6 1/8 Inches 206 Feet 350 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	9	.188	200	350

Perforations:
Type perforation Mill Slot
Size perforation 1/8 x 3
From 210 feet to 250 feet
From 330 feet to 350 feet
From feet to feet
From feet to feet
From feet to feet
Surface Seal: Yes No Seal Type:
 Neat Cement
Depth of Seal Cement Grout
Placement Method: Pumped Poured Concrete Grout
Gravel Packed: Yes No
From feet to feet

Date started 8-22-00, 19_____
Date completed 8-26-00, 19_____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	17	220	4

9. WATER LEVEL
Static water level 32 feet below land surface
Artesian flow none G.P.M. none P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name MILLER & SONS DRILLING CO. Contractor
Address P.O. Box 8056 Reno, NV 89507 Contractor
Nevada contractor's license number 37915 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller By driller performing actual drilling on site or contractor
Date 9-25-00