REPORT NO. A00.066

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

LOG NO. 82190
PERMIT NO.
BASIN 92A

NOTICE OF INTENT NO. 45599

OWNER Heather & Tim Curry
MAILING ADDRESS 11950 Overland Rd Reno NV 89506

ADDRESS OF WELL 11950 Overland Rd
Reno NV 89506

2. WELL LOCATION SE 1/4 NW 1/4 SEC. 15 T 21N R 19 E Washoe COUNTY

PERMIT NO ____ PARCEL NO 080-385-11 SUBDIVISION NAME Lemmon Valley

3. TYPE OF WORK
[ ] New Well [X] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [X] Mud

6. LITHOLOGIC LC

| MATERIAL | STRATA | FROM | TO | THICKNESS |
|---|---|---|---|---|
| Sand & DG | | 0 | 3 | 3 |
| Clay, sand & DG | | 3 | 30 | 27 |
| DG | | 30 | 50 | 20 |
| Green granite | | 50 | 55 | 5 |
| Black & white & green granite | | 55 | 140 | 85 |
| Green granite | | 140 | 385 | 245 |
| Black, green & gray granite | | 385 | 395 | 10 |
| S&P granite | X | 395 | 585 | 190 |
| Heavy gray clay | | 585 | 590 | 5 |

RECEIVED 00 DEC 11 PM 1:44 STATE ENGINEER'S OFFICE

Notes :
plugged by well log 113(63)

Date Started 11-27-00 Date Completed 12-6-00

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

| | GPM | DRAWDOWN | TIME (HRS) |
|---|---|---|---|
| | 20 | | 2.5 |
| | | | |
| | | | |

8. WELL CONSTRUCTION

Depth Drilled 590 Depth Cased 590

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 50 Feet
8 1/2 Inches 50 Feet 590 Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

| Size OD | Weight/Ft | Wall Thickness | From | To |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | +2 | 590 |
| | | | | |
| | | | | |
| | | | | |

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32x3
From 530 Feet to 570 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [X] Pumped [ ] Poured

SEAL TYPE:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 590 Feet

9. WATER LEVEL
Static Water Level 308 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATIOI
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981

Signed Roger L Thull
By driller performing actual drilling on site or contractor

Dated Dec 7-00