

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45042

1. OWNER TIM & HEATHER CURRY ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 11950 Overland
Reno, Nevada 89506

2. LOCATION NW 1/4 NW 1/4 Sec 15 T 21N N/S R 19 E Washoe County
 PERMIT NO. 080-385-11 Lemmon Valley Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL ABANDONMENT				
December 19, 2000	Day #1			
Total depth 398 feet				
Static Water Level 278 feet				
15 sacks of cement pumped.				
December 20, 2000	Day #2			
Cement level back to 318 feet				
Static Water Level at 277 feet				
15 sacks of cement pumped				
December 21, 2000	Day #3			
Cement level at 251 feet				
Cement above Static Water Level				
45 sacks of cement to fill casing to top.				
Cut casing below grade. Back fill excavation				
Total sacks of cement to plug well 75.				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From _____ To _____

Inches _____ Feet _____ Feet

Inches _____ Feet _____ Feet

Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:

Type perforation _____

Size perforation _____

From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level _____ feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

Date started December 19, 2000, 19
 Date completed December 21, 2000, 19

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510

Nevada contractor's license number 0022549
 issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923/908

Signed [Signature]
 Driller performing actual drilling on site or contractor

Date December 22, 2000

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 42815

1. OWNER TIM & HEATHER CURRY ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 11950 Overland Road
Reno, Nevada 89506

2. LOCATION NW 1/4 NW 1/4 Sec 15 T 21N N/S R 19 E Washoe County
 PERMIT NO. 080-385-11 Lemmon Valley
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING:				
Static water leve @285 feet				
Total depth @295 feet Yield only a mist.				
Fracture rock (app 1.5GPM)		295	297	2
Gray granite		297	328	31
Fracture (NO WATER)		328	330	2
Gray granite		330	336	6
Weathered granite		336	356	20
Fracture (NO WATER)		356	357	1
Weathered granite		357	381	24
Rusty weathered granite		381	395	14
Gray granite		395	405	10
Fracture (NO WATER)		405	406	1
Gray granite		406	448	42
Fracture (app 3 GPM)	X	448	449	1
Gray granite		449	469	20
Soft fractured granite w/clay streaks(1 GPM?)		469	491	22
Gray granite		491	500	9

NOTE: Bore hole caved in from 396 to 500 feet. At 336 ft. the 5" casing (liner) was collapsed from rock wedging against pipe. Casing could not be pulled or back driven from bore hole. Consider using well as is rather than pulling casing in two.

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 396 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 1/8 Inches 295 Feet 500 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	396

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 ground

From <u>196</u> feet to <u>216</u> feet
From <u>276</u> feet to <u>296</u> feet
From <u>336</u> feet to <u>356</u> feet
From <u>371</u> feet to <u>391</u> feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal deepening
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 285 feet below land surface
 Artesian flow _____ G.P.M. ³⁺ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. Contractor
 Address P.O. Box 12370 Contractor
Reno, Nevada 89510

Nevada contractor's license number issued by the State Contractor's Board 0022549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date September 20, 1999

Date started Sept. 7, 1999
 Date completed Sept. 13, 1999

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>3+</u>		