

OFFICE USE ONLY  
 Log No. 82195  
 Permit No. \_\_\_\_\_  
 Basin 87

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45095

1. OWNER M+E STEPHENS ADDRESS AT WELL LOCATION NW Cor of Melzerky Stephens  
 MAILING ADDRESS 5250 MT ROSE HWY 5250 MT ROSE HWY  
RENO, NV 89511 RENO NV 89511  
 2. LOCATION NW 1/4 SE 1/4 Sec 26 T. 18 N/S R 19 E County \_\_\_\_\_  
 PERMIT NO. 150 250 07 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>BLORS SAND, GRAVEL, BLACK GREY BLORS &amp; GRVL</u>		<u>28</u>	<u>280</u>	<u>280</u>
<u>BLK GREY VOL BLORS WITH SOME BRWN CLAY X</u>		<u>280</u>	<u>315</u>	<u>35</u>
<u>BLK GREY COLS, SAND &amp; GRVL</u>		<u>315</u>	<u>370</u>	<u>55</u>
<u>BLORS SAND + GRVL</u>	<u>X</u>	<u>370</u>	<u>380</u>	<u>10</u>

8. WELL CONSTRUCTION  
 Depth Drilled 380 Feet Depth Cased 380 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet  
0 Inches Feet 380 Feet  
0 Inches Feet \_\_\_\_\_ Feet  
0 Inches Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 5/8</u>	<u>13</u>	<u>.188</u>	<u>+2</u>	<u>380</u>

Perforations:  
 Type perforation SAWCUT  
 Size perforation 3 X 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 370 feet to 380 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 55  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 380 feet to 55 feet

9. WATER LEVEL  
 Static water level 240 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality \_\_\_\_\_

Date started 8/15, 1900  
 Date completed 8/22, 1900

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u>/</u>	<u>1 HR</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA DRILLING, INC Contractor  
 Address 75 LEWERS CRK RD Contractor  
CARSON CITY, NV 89704  
 Nevada contractor's license number issued by the State Contractor's Board 13697A  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1790  
 Signed Joe Feisch  
 By driller performing actual drilling on site or contractor  
 Date 8/28/00