WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 82243
Permit No.
Basin 84

NOTICE OF INTENT NO. 29532

1. OWNER Russell E Swain
MAILING ADDRESS 6100 Dietrick Ln
Reno, Nevada 89502

ADDRESS AT WELL LOCATION
5965 Gross Valley Road
Reno, Nevada

2. LOCATION SW ¼ NW ¼ Sec. 29 T. 23N N/S R. 21 E Washoe County

PERMIT NO. Issued by Water Resources | Parcel No. 077-360-15 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| c sand & gravel | | 0 | 4 | 4 |
| decomposed granite | | 4 | 110 | 106 |
| fractured basalt | x | 110 | 125 | 15 |
| black basalt | | 125 | 140 | 15 |
| fractured basalt | x | 140 | 158 | 18 |
| black basalt | | 158 | 180 | 22 |
| fractured basalt | x | 180 | 200 | 20 |

Date started 9-11-2000, 19
Date completed 9-12-2000, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 50+ | | 1 |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10.625 Inches | 0 Feet | 200 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6.625 | | .188 | 2+ | 200 |
| | | | | |

Perforations:
Type perforation Milled slot
Size perforation .125
From 100 feet to 120 feet
From 140 feet to 160 feet
From 180 feet to 200 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55 feet to 200 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow no G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Points West Drilling (Contractor)
Address P.O. Box 178 (Contractor)
West Point, Ca. 95255
Nevada contractor's license number issued by the State Contractor's Board 39825
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1974
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 9-17-2000

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627