


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 82251
 Permit No. _____
 Basin 61



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34328

1. OWNER Barrick Goldstrike Mines W-5 ADDRESS AT WELL LOCATION Barrick Goldstrike
 MAILING ADDRESS P.O. Box 29 minesite, north of Carlin, NV
Elko, NV 89803

2. LOCATION NW 1/4 SE 1/4 Sec. 20 T 36N N/S R 50E E Eureka County
 PERMIT NO. M/O 846 Issued by Water Resources Parcel No. N/A N/A Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Pulled pump out of well prior to abandoning.</u>				
<u>Abandoned by pumping hole plug from T.D. to 105', then capped with neat cement.</u>				
<u>Quantities Used:</u>				
<u>Cement: 10 cu.ft.</u>		<u>0</u>	<u>105</u>	<u>105</u>
<u>Hole plug: 3.5 cu.ft.</u>		<u>105</u>	<u>140</u>	<u>35</u>
<u>Construction Detail:</u>				
<u>Cement</u>		<u>0</u>	<u>7</u>	<u>7</u>
<u>Bentonite slurry</u>		<u>7</u>	<u>101</u>	<u>94</u>
<u>Bentonite pellets</u>		<u>101</u>	<u>113</u>	<u>12</u>
<u>Gravel pack</u>		<u>113</u>	<u>140</u>	<u>27</u>

Date started 12/16/2000, 19
 Date completed 12/16/2000, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 8.75 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>		<u>Sch 80 PVC</u>	<u>+3</u>	<u>140</u>

Perforations:
 Type perforation Slot
 Size perforation 0.020"

From _____	_____ feet to _____	_____ feet to _____
From _____	_____ feet to _____	_____ feet to _____
From _____	_____ feet to _____	_____ feet to _____
From _____	_____ feet to _____	_____ feet to _____

Surface Seal: Yes No Seal Type:
 Depth of Seal 7' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 113 feet to 140 feet

9. WATER LEVEL
 Static water level 115 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995

Signed Boye Jacobo
 By driller performing actual drilling on-site or contractor
 Date 1/2/01

B.S.T.L