

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 82252
 Permit No. _____
 Basin 61

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 43238-I

1. OWNER Barrick Goldstrike Mines PPW-91
 MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike
minesite, north of Carlin, NV.

2. LOCATION SE 1/4 NW 1/4 Sec. 30 T 36N N/S R 50E E Eureka County
 PERMIT NO. 55150 Issued by Water Resources Parcel No. NA Subdivision Name NA

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Note: The original well driller's report failed to indicate that hole plug was placed above the gravel pack, from 100' to 520'. This information was discovered on the client's as-built, and was conveyed to DWR. As a result, no perforating was done. The upper 361' of this well have been mined off. The construction data reflect the original construction.				
Abandoned by pumping abantonite via tremmie from T.D. to 240', hole plug to 15', capped with neat cement.				
Quantities Used:				
Cement: 3 cu.ft.		0	15	15
Hole plug: 44 cu.ft.		15	240	225
Abantonite: 331 cu.ft.		240	700	460

8. WELL CONSTRUCTION

Depth Drilled 1360 Feet Depth Cased 1340 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>17.500</u>	<u>0</u>	<u>70</u>		
<u>9.875</u>	<u>70</u>	<u>1360</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12.750</u>	<u>27.4</u>	<u>0.250</u>	<u>0</u>	<u>70</u>
<u>6.625</u>	<u>17.02</u>	<u>0.250</u>	<u>+1</u>	<u>1340</u>

Perforations:
 Type perforation Louver
 Size perforation 0.125"

From	To	Feet	Feet
<u>540</u>	<u>1340</u>		

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal: 100'

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 100 feet to 1350 feet

9. WATER LEVEL

Static water level 468 feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1888

Signed David Woriot
 By driller performing actual drilling on-site or contractor

Date 8/29/2000

Date started 8/14/2000, 19
 Date completed 8/15/2000, 19

7. WELL TEST DATA

TEST METHOD:	DRAW DOWN		TIME (HOURS)
	FEET BELOW STATIC	G.P.M.	
<u>TEST METHOD:</u>	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
<u>TEST METHOD:</u>			

RECEIVED
 00SEP - 1 AM 11:20
 STATE ENGINEERING DEPT.

BST-L