WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82267
Permit No.
Basin 162

NOTICE OF INTENT NO. 20214

1. OWNER MARK SOILEAU
MAILING ADDRESS 1040 N. Barney
Pahrump NV 89060

ADDRESS AT WELL LOCATION
3000 W IRENE ST
PAHRUMP NV 89060

2. LOCATION SE ¼ SE ¼ Sec. 1 T. 20S N/S R. 52 E. Nye County
PERMIT NO. 28-433-26 (Issued by Water Resources) 28-433-26 (Parcel No.) Vegas Acres U1 LOT 168 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SURFACE		0	4	4
GREY CLAY		4	14	10
BROWN CLAY		14	36	22
GREY CLAY		36	48	12
HARD SPOT		48	52	4
GREY CLAY	X	52	92	40
HARD SPOT (clay)		92	98	6
SOFT BROWN CLAY	X	98	140	42

DCNR/DWR Received FEB 14 2001 LAS VEGAS OFFICE

Date started 2-07-2001, 19
Date completed 2-08-2001, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	-0-	15 min

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
12	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	17#	.188	0	140

Perforations:
Type perforation TORCH CUT
Size perforation ¼" WIDE X 8" LONG
From 100 feet to 148 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CHARLES NYBERG Well Drilling (Contractor)
Address 1060 W. BASIN AVE (Contractor)
Pahrump NV 89060
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725
Signed Charles Nyberg CRD
By driller performing actual drilling on site or contractor
Date 2-8-2001

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627