WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82284
Permit No. 65309
Basin 212

NOTICE OF INTENT NO. 20026

1. OWNER Joe ~~Cannarvo~~ CANNAVO-City Auto
MAILING ADDRESS 2220 N. Commerce
North Las Vegas, NV 89030
ADDRESS AT WELL LOCATION 5170 COPPER SAGE N.L.V.
~~Same~~ S.

2. LOCATION NE ¼ SW ¼ Sec. 32 T. 19 N/S R. 62 E. Clark County
PERMIT NO. 65309 Issued by Water Resources
123-32-301-017 Parcel No.
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & gravel		0	10	10
Clay-brown		10	34	24
Sand-brown		34	68	34
Sand & clay		68	102	34
Gravel		102	106	4
Clay-brown	x	106	120	14
Gravel	x	120	136	16
Sandy Clay		136	169	33
Gravel		169	172	3
Sandy clay		172	227	55
Gravel	X	227	235	7
Sandy clay		235	242	7
Gravel	X	242	251	11

Date started 2/01/01, 19
Date completed 2/6/01, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 251 Feet Depth Cased 251 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	251 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8		.188	+1	250

Perforations:
Type perforation mill slot
Size perforation 1/4 x 2
From 150 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 250 feet

9. WATER LEVEL
Static water level 102 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling Co., Inc. Contractor
Address 7227 Hauck Street Contractor
Las Vegas, NV 89030
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2120
Signed Richard K. Thompson By driller performing actual drilling on site or contractor
Date 2-7-01

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627