

PRINT OR TYPE ONLY  
 NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21782

1. OWNER Micheal Quick ADDRESS AT WELL LOCATION  
 MAILING ADDRESS 6120 Akerman LV Nev  
Ackerman Ave  
 2. LOCATION SE 1/4 SE 1/4 Sec. 11 T 19S N/S R 60 E Clark County  
 PERMIT NO. 125-11-803-014  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Popcofn Caliche		0	35	
Caliche		35	50	
Clay & Sand		50	185	
Caliche & Water	xx	185	195	
Clay & Sand		195	360	
Caliche & Water	xx	360	400	
Clay & Sand		400	460	
Caliche & Water	xx	460	480	
Clay & Sand		480	620	
Caliche & Water	xx	620	640	

8. WELL CONSTRUCTION  
 Depth Drilled 640 Feet Depth Cased 640 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
12 1/4 Inches 0 Feet 55 Feet  
8 3/8 Inches 55 Feet 640 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	640

 Perforations:  
 Type perforation Factory  
 Size perforation .020 Sieve Type  
 From 590 feet to 630 feet  
 From 590 feet to 630 feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 9. WATER LEVEL  
 Static water level 158 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COOL °F Quality \_\_\_\_\_

Date started 1-31-01, 19\_\_\_\_\_  
 Date completed 2-6-01, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Vernon H. Dimick Contractor  
 Address 5360 Bonita Vista Contractor  
Las Vegas, Nev. 89149  
 Nevada contractor's license number 10062  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the 552  
 Division of Water Resources, the on-site driller.  
 Signed VH Dimick  
 By driller performing actual drilling on site or contractor  
 Date 2-6-01

