


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 82289
 Permit No. 61457
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20896

1. OWNER VALLEY ELECTRIC ASSOCIATION
 MAILING ADDRESS
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 3350 E THOUSANDAIRE

2. LOCATION SE 1/4 SW 1/4 Sec. 7 T 21S
 PERMIT NO. 61457 Issued by Water Resources
45-081-15 Parcel No.

N/S R 54E E NYE County

Subdivision Name

3. WORK PERFORMED

- New Well
 Replace
 Recondition
 Deepen
 Abandon
 Other

4. PROPOSED USE

- Domestic
 Municipal/Industrial
 Irrigation
 Monitor
 Test
 Stock

5. WELL TYPE

- Cable
 Rotary
 RVC
 Air
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY & CALICHIE		0	75	75
CALICHIE	WB	75	90	15
CLAY		90	104	14
CALICHIE	WB	104	117	13
CLAY		117	133	16
CALICHIE	WB	133	148	15
CLAY		148	167	19
CALICHIE	WB	167	182	15
CLAY		182	200	18

8. WELL CONSTRUCTION

Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

10.25 Inches From 0 Feet To 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>12.92</u>	<u>.188</u>	<u>0</u>	<u>200</u>

Perforations:

Type perforation FACTORY SAW CUT

Size perforation 1/8 X 3

From 160 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No

Depth of Seal 50

Placement Method: Pumped

Poured

Seal Type:

Neat Cement

Cement Grout

Concrete Grout

Gravel Packed: Yes No

From 50 feet to 200 feet

9. WATER LEVEL

Static water level 68 feet below land surface

Artesian flow _____ G.P.M. _____ P.S.I.

Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.

Contractor

Address P.O. BOX 4220

Contractor

PAHRUMP, NV. 89048

Nevada contractor's license number

issued by the State Contractor's Board 47333

Nevada driller's license number issued by the

Division of Water Resources, the on-site driller 2063

Signed Thomas Dam

By driller performing actual drilling on-site or contractor

Date 1/22/01



7. WELL TEST DATA

TEST METHOD:

Baller

Pump

Air Lift

G.P.M.

Draw Down
(Feet Below Static)

Time (Hours)

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

USE ADDITIONAL SHEETS IF NECESSARY