WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82294
Permit No.
Basin 162

NOTICE OF INTENT NO. 20926

1. OWNER PAHRUMP CONCRETE
MAILING ADDRESS 6321 CONESTOGA
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 6321 CONESTOGA

2. LOCATION SW 1/4 NE 1/4 Sec. 13 T 21S N/S R 53E E NYE County
PERMIT NO. (Issued by Water Resources) 44-591-16 (Parcel No.) CONESTOGA COUNTRY ESTATES (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	25	25
CALICHIE		25	31	6
CLAY		31	56	25
CALICHIE		56	59	3
CLAY		59	73	14
CALICHIE	WB	73	84	11
CLAY		84	109	25
CALICHIE	WB	109	123	14
CLAY		123	130	7
CALICHIE	WB	130	140	10

DCNR RECEIVED FEB 21 2001 LAS VEGAS OFFICE

Date started 2/12/2001, 19__
Date completed ~~2/12/2018~~ 2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	3.63	.280	0	140

Perforations:
Type perforation SAW CUT
Size perforation 1/8 X 3
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 67 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on-site or contractor)
Date 2/16/2001

USE ADDITIONAL SHEETS IF NECESSARY