

OFFICE USE ONLY  
 Log No. 82370  
 Permit No. 001  
 Basin. 115197

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 115197

1. OWNER Lance Litchy ADDRESS AT WELL LOCATION Reble RD ADJACENT SR292  
 MAILING ADDRESS P.O. Box 210  
Denio, NV 89804  
 2. LOCATION NW 1/4 NW 1/4 Sec 4 T. 47 N/S R 30 E Humboldt County  
 PERMIT NO. Domestic Issued by Water Resources Parcel No. 02-01d-13 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>top soil</u>		<u>0</u>	<u>15</u>	<u>15</u>
<u>sand</u>		<u>15</u>	<u>40</u>	<u>25</u>
<u>gravel</u>		<u>40</u>	<u>60</u>	<u>20</u>
<u>sand</u>		<u>60</u>	<u>70</u>	<u>10</u>
<u>clay</u>		<u>70</u>	<u>100</u>	<u>30</u>
<u>gravel</u>	<u>yes</u>	<u>100</u>	<u>110</u>	<u>10</u>

8. WELL CONSTRUCTION  
 Depth Drilled 110 Feet Depth Cased 110 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 0 Feet 110 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>10</u>	<u>1 8/8</u>	<u>1</u>	<u>110</u>

 Perforations:  
 Type perforation Factory Cut  
 Size perforation 3/32 x 4  
 From 100 feet to 110 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 110 feet to 50 feet

RECEIVED  
 000628 AM 9:03  
 STATE ENGINEER'S OFFICE

Date started OCT 10 2000  
 Date completed OCT 13 2000

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		<u>4</u>

9. WATER LEVEL  
 Static water level 28 feet below land surface  
 Artesian flow N/A G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FRED AWARON Contractor  
 Address 10760 Grass Valley RD  
Winnemucca, NV  
 Nevada contractor's license number 021467  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 01375  
 Division of Water Resources, the on-site driller  
 Signed \_\_\_\_\_  
 Date Nov 1 00