

OFFICE USE ONLY
 Log No. 82398
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19112

1. OWNER Gerardi ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1841 W. Vandell Dr. Pahrump, NV 89048 1841 W. Vandell Dr. Pahrump, NV 89048
 2. LOCATION NW 1/4 SW 17 T 20 N 33 E N1/4 County _____
 PERMIT NO. 36293-10 Parcel No. _____ Subdivision Name Cal Vegas Ranchos
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
clay		0	10'	10'
white clay		10'	25'	15'
caliche		25'	30'	5'
brown clay		30'	55'	25'
white clay		55'	70'	15'
caliche		70'	75'	5'
brown clay		75'	90'	15'
white clay		90'	100'	10'
caliche		100'	105'	5'
brown clay		105'	130'	25'
white clay		130'	140'	10'

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 140
12 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.625</u>	<u>4.33</u>	<u>1.316</u>	<u>0</u>	<u>140'</u>

Perforations:
 Type perforation slur cut
 Size perforation 1/8" x 3'
 From 100' feet to 140' feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50' feet to 140' feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 1/29 2001
 Date completed 2/2 2001

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lake Construction Co.
 Address 4191 S. Peckle St Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 0049225
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 2116
 Signed Forest Lake
 By driller performing actual drilling on site or contractor
 Date March 5, 2001