WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82401
Permit No.
Basin 162

NOTICE OF INTENT NO. 19116

1. OWNER Bernard
MAILING ADDRESS 3340 W. Sherry St.
ADDRESS AT WELL LOCATION 3340 W. Sherry St. Pahrump, Nevada 89048

2. LOCATION NW ¼ SE ¼ Sec. 25 T. 19 N ⊗ R. 52 E. Nye County
PERMIT NO. (Issued by Water Resources) 28-242-05 (Parcel No.) Bell Vista Unit 4 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown sandy clay		0	10'	10'
clay		10'	25'	15'
soft brown clay		25'	55'	30'
white clay		55'	65'	10'
brown sandy clay		65'	80'	15'
clay		80'	95'	15'
grey clay		95'	120'	25'
white clay		120'	130'	10'
brown clay		130'	140	10'

Date started March 2, 2001
Date completed March 4, 2001

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	4.33	.316	0	140

Perforations:
Type perforation Saw cut
Size perforation 1/8" x 3"
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) LaRue Construction Company
Address (Contractor) 4191 S. Jackie St.
Pahrump Nevada 89048
Nevada contractor's license number issued by the State Contractor's Board 0049228
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2116
Signed Forest LaRue (By driller performing actual drilling on site or contractor)
Date March 5, 2001

DCNR DWR Received MAR 12 2001 LAS VEGAS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627