REPORT NO. A01.003

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO 82405
PERMIT NO.
BASIN 103
NOTICE OF INTENT NO. 45608

OWNER Phil & Mary Clark
MAILING ADDRESS 240 Sutro Rd Dayton NV 89403

ADDRESS OF WELL 240 Sutro Rd
Dayton NV 89403

2. WELL LOCATION NE 1/4 NE 1/4 SEC. 8 T 16N R 22 E Lyon COUNTY

PERMIT NO ____ PARCEL NO 016-352-07 SUBDIVISION NAME Dayton

3. TYPE OF WORK
[ ] New Well [ ] Replace [X] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Mud

6. LITHOLOGIC LC

MATERIAL	STRATA	FROM	TO	THICKNESS

RECEIVED
01 FEB 22 PM 12:54
STATE ENGINEER'S OFFICE

Notes : Trip in & clean well. 4' fill. Concrete plug @ 190'. Clean 40' of perf. Went from 4 gpm to 18 gpm

Date Started 01-22-01 Date Completed 01-22-01

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20	69'	40 MIN

8. WELL CONSTRUCTION

Depth Drilled ____ Depth Cased ____

HOLE DIAMETER (BIT SIZE)
____ Inches ____ Feet ____ Feet
____ Inches ____ Feet ____ Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To

PERFORATIONS:
Type Perforation ____ Size Perforation ____
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [ ] Yes [ ] No
Seal Depth ____
PLACEMENT METHOD: [ ] Pumped [ ] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [ ] Yes [ ] No
From ____ Feet to ____ Feet

9. WATER LEVEL
Static Water Level 58' Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature Cool F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 1981

Signed [signature]
By driller performing actual drilling on site or contractor

Dated Feb 19-01