WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82414
Permit No. 96
Basin

NOTICE OF INTENT NO. 14297

1. OWNER Sal Randazzo
MAILING ADDRESS 77 Via Descanso Monterey CA 93940
ADDRESS AT WELL LOCATION 655 Thoroughbred Cir Reno NV 89506

2. LOCATION SE ¼ NE ¼ Sec. 21 T. 23 N/S R. 18 E. Washoe County
PERMIT NO. Issued by Water Resources
078-101-18 Parcel No.
Rancho havin Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Boulders		0	101	101
Red Clay		101	115	14
Sand & Rocks		115	140	25
Broken DG		140	180	40
Sand & Boulders		180	284	104

Date started 10-27-00, 19
Date completed 11-21-00, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10+		25 hrs

8. WELL CONSTRUCTION
Depth Drilled 284 Feet Depth Cased 246 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	50 Feet
8 Inches		50 Feet	85 Feet
6 1/8 Inches		85 Feet	284 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	140
5 9/16	12	.188	2+	246

Perforations:
Type perforation Saw Slot & Touch
Size perforation 3/16 x 3 1/2
From 246 feet to 226 feet SS
From 226 feet to 146 feet Touch
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 246 feet

9. WATER LEVEL
Static water level 28 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Olenski Drilling Contractor
Address 15045 Red Rock Rd Contractor
Reno NV 89506
Nevada contractor's license number issued by the State Contractor's Board 50343
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
Signed [signature] By driller performing actual drilling on site or contractor
Date 11/25/00

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627