

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 200698

1. OWNER Heis Wable ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
1520 W. Wilson Rd. Same
 2. LOCATION SE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 17 T. 20S N/S R. 53E E. Nye County
 PERMIT NO. _____ Parcel No. 36-282-87 Subdivision Name _____
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____


6. LITHOLOGIC LOG

Material	Water Strain	From	To	Thick-ness
Brown Clay		0	4	4
Grey Clay		4	35	31
Light Brown		35	55	20
Grey Clay		55	70	15
Caliche		70	73	3
Grey Clay	X	73	105	32
Caliche	X	105	107	2
Brown Clay	X	107	140	33

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC	Sch 40	0	14

Perforations:
 Type perforation Saw
 Size perforation 1.5 x 6
 From _____ feet to _____ feet
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet



Date started 3-1-01, 19__
 Date completed 3-4-01, 19__

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	5	1 1/2

9. WATER LEVEL
 Static water level 74' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Pahrump Water Well Service Contractor
 Address P.O. Box 3390 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 0035901
 Nevada driller's license number issued by the Division of Water Resources 1916
 Signed Darryl Humber
 By driller performing actual drilling on site or contractor
 Date March 27, 2001