WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 82446
Permit No.
Basin 230

NOTICE OF INTENT NO. 21666

1. OWNER Dave Hagan
MAILING ADDRESS 945 S. Faith
Amargosa Valley, Nv. 89020

ADDRESS AT WELL LOCATION 45 S. Faith
Amargosa Valley, NV 89020

2. LOCATION NW ¼ NW ¼ Sec. 35 T. 16 N/S R. 49 E. NYE County

PERMIT NO. Issued by Water Resources | 19-631-16 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVD
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
large gravel		4	7	3
snd.		7	45	38
gravel		45	61	16
brown cly.		61	72	11
compact gravel		72	78	6
snd.		78	85	7
compact. gravel	1st	85	92	7
snd.		92	100	8
limestone		100	112	12
snd. w/gravel layers		112	120	8
limestone w/ snd layers		120	155	35
snd.		155	180	25
limestone w/cly.		180	200	20
Bottom of Hole			200	

DCNR/DWR Received MAR 28 2001 LAS VEGAS OFFICE

Date started Feb. 27, 2001
Date completed March 1, 2001

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12½	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	PVC		0	200
Surface Protective Casing: 7"X 8" steel		.1808		

Perforations:
Type perforation Machined
Size perforation 3" x 1/8" every 12"
From 120 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality ~~clear~~

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co. Contractor
Address HCR 70 Box 543 Contractor
Amargosa Valley, NV 89020
Nevada contractor's license number issued by the State Contractor's Board 5376 A
Nevada driller's license number issued by the Division of Water Resources, the on site driller 2160
Signed [signature] By driller performing actual drilling on site or contractor
Date 3/5/01

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627