

OFFICE USE ONLY  
 Log No. 82495  
 Permit No. 104  
 Basin. I  
 37424

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 37424

1. OWNER CITY OF CARSON CITY ADDRESS AT WELL LOCATION EVERGREEN GOING EAST ON COLLEGE BLVD  
 MAILING ADDRESS 3308 BUTTE WAY BLDG 1 CARSON CITY NV 89101 Well # 5  
 2. LOCATION 1/4 SW 1/4 Sec. 5 T 15 N/S R 20 E CARSON CITY County  
 PERMIT NO. DEW 023 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic DEWATER  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other AUSEK

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>SILTY CLAY</u>	<u>8</u>	<u>0</u>	<u>8</u>	
<u>SILTY SAND</u>		<u>8</u>	<u>9</u>	
<u>CEMENTED SAND</u>		<u>9</u>	<u>15</u>	
<u>SANDY CLAY</u>		<u>15</u>	<u>25</u>	
<u>CLAY</u>		<u>25</u>	<u>30</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 30 Feet Depth Cased 30 Feet  
 HOLE DIAMETER (BIT SIZE)  
24 Inches From 0 Feet To 30 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>6</u>	<u>.375</u>	<u>10</u>	<u>30</u>

Perforations:  
 Type perforation SLOT  
 Size perforation .030"  
 From 10 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal N/A  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 10 feet to 30 feet

Date started April 6 2000  
 Date completed April 6 2000

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 8 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Viking Drillers, Inc. Contractor  
 Address 801 NORTHPORT DRIVE Contractor  
WEST SACO, CA, 95691  
 Nevada contractor's license number 00044407  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the M-2091  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 10-9-00