

OFFICE USE ONLY

Log No. 82531
 Permit No. _____
 Basin 203

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21501

1. OWNER Mike Reese ADDRESS AT WELL LOCATION None
 MAILING ADDRESS Panaca, Nevada PANACA, NV

2. LOCATION NW 1/4 NW 1/4 Sec. 33 T 1 N 8 R 68 El Incon County
 PERMIT NO. 125046-05 Issued by Water Resources Parcel No. None Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>clay with tubes</u>		<u>0</u>	<u>70</u>	<u>70</u>
<u>Basal gravel & Boulders</u>				
<u>gravel with Boulders</u>	<u>X</u>	<u>70</u>	<u>76</u>	<u>6</u>
<u>clay with gravel & Boulders</u>		<u>76</u>	<u>110</u>	<u>34</u>
<u>Boulders & gravel</u>	<u>X</u>	<u>110</u>	<u>125</u>	<u>15</u>
<u>clay with Boulders</u>		<u>125</u>	<u>155</u>	<u>30</u>
<u>Basal Rock, vol. Tubr.</u>	<u>X</u>	<u>155</u>	<u>168</u>	<u>13</u>

8. WELL CONSTRUCTION
 Depth Drilled 168 Feet Depth Cased 168 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 168
12 Inches 0 Feet 168 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>27</u>	<u>.250</u>	<u>0</u>	<u>168</u>

Perforations:
 Type perforation Torch
 Size perforation 1/4 x 2 1/2
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 168 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 100 °F Quality UNKNOWN

Date started Aug 5, 2000
 Date completed Sept 10, 2000

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>30</u>	<u>2 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christianson Drilling Inc. Contractor
 Address ELY Nev. Contractor
 Nevada contractor's license number 0014790 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 783
 Signed Ronald K. Amador
 By driller performing actual drilling on site or contractor
 Date 10-5-01